

HWSA PFOS/PFOA Sampling Results Inactive Sources as of 2/17/17
 red text indicates well was NOT supplying public system when sample was taken

Source or Well No.	Sample Collection Date	PFOS Result (ppt ¹)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt ²)
1	6/24/2014	ND ³	ND ³	ND ³	
1	12/5/2014	ND ³	ND ³	ND ³	
1	12/15/2015	6.1	12.0	18.1	
1	5/10/2016	6.8	7.5	14.3	
1	7/27/2016	well out of service for maintenance			70.0
1	8/11/2016	9.2	11.0	20.2	70.0
1	9/22/2016	8.7	12.0	20.7	70.0
1	10/12/2016	8.9	11.0	19.9	70.0
1	10/25/2016	6.3	15.0	21.3	70.0
1	11/9/2016	9.0	9.6	18.6	70.0
1	12/1/2016	11.0	12.0	23.0	70.0
1	1/11/2017	4.6	8.3	12.9	70.0
1	2/7/2017		pending		70.0
well suspended from service 1/27/17 in accordance with short term plan					
2	6/25/2014	ND ³	ND ³	ND ³	
2	12/12/2014	ND ³	ND ³	ND ³	
2	12/15/2015	16.0	17.0	33.0	
2	5/10/2016	18.0	10.0	28.0	
2	7/27/2016	23.0	14.0	37.0	70.0
2	8/10/2016	27.0	16.0	43.0	70.0
2	9/22/2016	39.0	19.0	58.0	70.0
2	10/12/2016	21.0	16.0	37.0	70.0
2	10/25/2016	20.0	22.0	42.0	70.0
2	11/9/2016	21.0	14.0	35.0	70.0
2	12/1/2016	14.0	9.6	23.6	70.0
2	1/11/2017	9.6	9.1	18.7	70.0
2	2/7/2017		pending		70.0
well suspended from service 11/18/16 in accordance with short term plan well suspended from service well suspended from service					
9	6/25/2014	ND ³	ND ³	ND ³	
9	12/12/2014	ND ³	ND ³	ND ³	
9	12/15/2015	5.7	7.6	13.3	
9	5/10/2016	5.1	4.5	9.6	
9	7/27/2016	8.6	6.8	15.4	70.0
9	8/10/2016	11.0	6.6	17.6	70.0
9	9/22/2016	13.0	11.0	24.0	70.0
9	10/12/2016	14.0	11.0	25.0	70.0
9	10/25/2016	16.0	8.9	24.9	70.0
9	11/9/2016	14.0	8.8	22.8	70.0
9	12/1/2016	13.0	9.0	22.0	70.0
9	1/11/2017	5.9	6.4	12.3	70.0
9	2/7/2017		pending		70.0
well suspended from service 1/27/17 in accordance with short term plan					
10	6/24/2014	41.0	20.0	61.0	
10	8/28/2014	43.0	22.0	65.0	
10	11/5/2014	30.0	25.0	55.0	
10	12/9/2014	45.0	26.0	71.0	
10	1/28/2015	24.0	20.0	44.0	
10	2/25/2015	25.0	21.0	46.0	
10	3/25/2015	17.0	14.0	31.0	
10	4/15/2015	22.0	20.0	42.0	
10	5/28/2015	41.0	19.0	60.0	
10	6/18/2015	40.0	19.0	59.0	
10	7/22/2015	14.0	14.0	28.0	
10	8/13/2015	23.0	22.0	45.0	
10	9/24/2015	24.0	25.0	49.0	
10	10/14/2015	21.0	17.0	38.0	
10	11/23/2015	23.0	23.0	46.0	
10	12/15/2015	22.0	18.0	40.0	
10	1/19/2016	41.0	18.0	59.0	
10	2/12/2016	19.0	14.0	33.0	
10	3/16/2016	20.0	48.0	68.0	
10	4/13/2016	16.0	12.0	28.0	
10	5/10/2016	30.0	15.0	45.0	
10	7/27/2016	39.0	19.0	58.0	70.0
10	8/10/2016	50.0	25.0	75.0	70.0
10	9/22/2016	39.0	27.0	66.0	70.0
10	10/12/2016	70.0	45.0	115.0	70.0
10	10/25/2016	61.0	38.0	99.0	70.0
10	11/9/2016	76.0	42.0	118.0	70.0
Well taken out of service 5/19/16 well began running to waste w/temp GAC 7/25/16 samples are RAW water only well running to waste w/temp GAC samples are RAW water only well running to waste w/temp GAC samples are RAW water only samples are RAW water well pumping suspended 10/6/16 pending DEP approval for expanded pilot study, pump in hand to take sample samples are RAW water only well pumping suspended, pumped in hand to take sample samples are RAW water only well pumping suspended, pumped in hand to take sample					

HWSA PFOS/PFOA Sampling Results Inactive Sources as of 2/17/17
 red text indicates well was NOT supplying public system when sample was taken

Source or Well No.	Sample Collection Date	PFOS Result (ppt ¹)	PFOA Result (ppt)	Combined PFOS PFOA total concentration (ppt)	Combined PFOS PFOA Health Advisory issued 5/19/16 (ppt ²)
10	12/1/2016	49.0	22.0	71.0	70.0
10	1/11/2017	26.7	23.3	50.0	70.0
10	2/8/2017		pending		70.0
19	6/24/2014	ND ³	ND ³	ND ³	
19	12/8/2014	ND ³	ND ³	ND ³	
19	12/15/2015	6.4	9.2	15.6	
19	5/10/2016	7.8	6.3	14.1	
19	7/27/2016	12.0	7.5	19.5	70.0
19	8/10/2016	14.0	8.6	22.6	70.0
19	9/22/2016	10.0	9.5	19.5	70.0
19	10/12/2016	13.0	9.6	22.6	70.0
19	10/25/2016	10.0	8.4	18.4	70.0
19	11/9/2016	12.0	9.0	21.0	70.0
19	12/1/2016	12.0	7.7	19.7	70.0
19	1/11/2017	6.8	6.7	13.5	70.0
19	2/7/2017		pending		70.0
20	6/24/2014	ND ³	ND ³	ND ³	
20	12/12/2014	ND ³	ND ³	ND ³	
20	12/15/2015	12.0	14.0	26.0	
20	5/10/2016	11.0	9.0	20.0	
20	7/27/2016	19.0	13.0	32.0	70.0
20	8/10/2016	21.0	14.0	35.0	70.0
20	9/22/2016	17.0	15.0	32.0	70.0
20	10/12/2016	23.0	17.0	40.0	70.0
20	10/25/2016	26.0	20.0	46.0	70.0
20	11/9/2016	27.0	16.0	43.0	70.0
20	12/1/2016	24.0	15.0	39.0	70.0
20	1/11/2017	10.2	8.2	18.4	70.0
20	2/7/2017		pending		70.0
26	6/24/2014	700.0	290.0	990.0	
26	2/8/2017		pending		70.0
40	6/24/2014	1000.0	63.0	1063.0	
40	1/11/2017	ND ⁵	ND ⁵	ND ⁵	70.0
40	2/8/2017		pending		70.0

samples are RAW water
 received DEP approval for extension of pilot with resin 11/28/16
 resumed pumping to waste w/ temp GAC & resin addition 11/29/16
 well running to waste w/temp GAC & resin
 samples are RAW water only

well suspended from service 2/8/17 in accordance with short term plan

well suspended from service 12/15/16 in accordance with short term plan
 well suspended from service

Well taken out of service 7/30/14
 Began running to waste w treatment system in test mode 1/17/17

Well taken out of Service 7/30/14
 Began running to waste w treatment system in test mode 1/11/17
 Sample results are treated water

¹ Parts Per Trillion - equivalent to ng/L (nanograms per liter).
² The Health Advisory was issued on May 19, 2016 as 70 parts per trillion.
³ ND - Not Detected - Results below laboratory minimum reporting limit of 40 ppt for PFOS & 20 ppt for PFOA
⁴ ND - Not Detected - Results below laboratory minimum reporting limit of 30 ppt for PFOA
⁵ ND - Not Detected - Results below laboratory minimum reporting limit of 2.5 ppt for each PFOS & PFOA
⁶ ND - Not Detected - Results below laboratory minimum reporting limit of 4 ppt for PFOS
⁷ ND - Not Detected - Results below laboratory minimum reporting limit of 2 ppt for PFOA
⁸ samples were collected at a distribution site representative of the interconnect
⁹ ND - Not Detected - Results below laboratory minimum reporting limit of 2.4 ppt for each PFOS & PFOA
 green text indicates EPA UCMR3 compliance sample